

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2023/ 309

Dated: - 12/06/2023

To,

The Principal,  
Ramjas Public School (Day Boarding),  
Anand Parbat, New Delhi- 110005.

Sub:- Regarding issued/renewal of Fire Safety Certificate in r/o Ramjas Public School (Day Boarding), Anand Parbat, New Delhi- 110005.

Sir,

Please refer to your letter No. RDB/ADM/01/2023-24/28 dated 02.05.2023, on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officers concerned of this department in presence of Ms. Sarika Arora (Principal) on dated 31.05.2023 to check the functionability of the existing fire safety arrangements in the school building.

During the inspection, it has been observed that the said school building having three wings, namely Primary Wing, Secondary Wing & Nursery Wing. Primary wing & Secondary wing each having ground plus two upper floors and Nursery wing having ground floor only. However, at the time of inspection the following shortcomings were observed:-

1. Fire extinguisher found provided but not refilled.
2. First-Aid hose reels found provided but not covering all area of floors.
3. Overhead water storage tank found empty.
4. Exit Signage found not provided.

In view of the above shortcomings, 'Fire Safety Certificate' cannot be issued/renewal at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department.


Yours faithfully

  
(Atul Garg)  
Director

Delhi Fire Service

Copy to: -

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

  
for information please.