

C 25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2023/SZ/305

Dated: 12/06/2023

To

Principal,
Rattan Chand Arya Public School,
Arya Samaj Mandir, Y Block, Sarojini Nagar,
New Delhi- 110023.

Sub.:- NOC in r/o Rattan Chand Arya Public School, Arya Samaj Mandir, Y Block, Sarojini Nagar, New Delhi-110023..

Sir,

With reference to your letter No. RCAPS/2023/19 dated 26/04/2023 on the subject noted above, in this connection it is to inform you that the said building premises was inspected by the officer concerned of this department on 08/05/2023 in the presence of Mrs. Khanduri Abha (Principal). During the course of inspection it was observed that the building premises is comprised of Ground Floor + Two upper Floors only and following shortcomings were observed:-

1. Hose reel system found non functional.
2. Fire fighting Pumps found nonfunctional and required to be on auto mode.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
Delhi Fire Service
01

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.