



75
Azadi Ka
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/EH/2023/NDZ/ 310

Dated: 13/06/2023

To,

The Manager
Honey & Dough (Eating House)
Plot No. 115, Hargovind Enclave,
Delhi-110092

Sub:- Regarding Issuance of Fire Safety Certificate in r/o M/s Honey & Dough (Eating House) located Plot No. 115, Hargovind Enclave, Delhi-110092.


Sir,

With reference to your online MHA application No. 2023050808442 dated 09/05/2023 on the subject cited above. In this connection, it is to inform you that the officers concerned of this department has carried out the inspection of the premises from fire safety point of view in presence of Sh. Ravinder, Manager on dated 27/05/2023. The building comprised of ground plus three upper floors. Proposed Eating House is on ground floor. Following shortcomings were observed during the time of inspection:-

1. One door of width 1.50 meter is provided against two doors of width 1.50 meter each.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony, New Delhi