



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No F6/DFS/MS/BP/2023/ 127

Dated 14/06/2023

To,

The Executive Engineer -I (Bldg)HQ
Municipal Corporation of Delhi,
9th Floor, Civic Centre, Minto Road,
New Delhi – 110002

Sub: Online building plan in r/o Plot No. A - 20, Naraina Industrial Area, Phase-I, New Delhi - 110028.

Sir,

Please refer your Request ID No 10115583 dated 06-06-2023 on the subject cited above. In this connection this is to inform you that the online building plans of above said industrial building have been scrutinized by this department from fire and life safety point of view and observed following shortcomings

- 1 Information, provided in CAF is not as per NBC-IV/UBBL-2016
- 2 Lifts are opening in staircase, which is violation of clause 7.11 (o) of UBBL – 2016
- 3 Opening in staircases is not meeting the requirement of clause 4.4.2.4.3.4 (d) of NBC- Part-4.

Therefore, plans are rejected with request to rectify above shortcomings and re-submit plans for further consideration in the matter

Yours faithfully

(ATUL GARG)
DIRECTOR

Ph 011-23414000

mf/c *e b c*