



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/2023/Indl/1228

Dated: 13/06/2023

To

Sh. Chasvinder Singh
Plot No.03, S.S.I, Co-operative
Industrial Estates, G.T. K. Road,
Delhi-110033

Sub: Regarding renewal of Fire Safety Certificate in r/o Shanti Steel Pvt. Ltd. located at Plot No.03, S.S.I, Co-operative Industrial Estates, G.T. Karnal Road, Delhi-110033

Sir,

Kindly refer to your letter no. Nil and received in this department vide outdoor dairy no. 2450 dated: 01.06.2023 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 07.06.2023 to verify the fire safety arrangements installed in the building as per issued fire safety recommendations vide letter of even no. 1865 dated 10.11.1993. At the time of inspection Sh. Sharabjeet Singh (Maintenance Manager) was also present at site. During the course of the inspection it is observed that the building is comprised of basement, mezzanine, ground & first floor only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings

1. Smoke ventilation systems is provided in the basement but found not functional at the time of inspection.
2. Hose reel hose provided but found nonfunctional.
3. Internal Hydrants & Yard hydrants provided in the building but found not functional.
4. Ground level fire pump capacity of 900lpm provided but not functional.
5. Exit & floor signage's found removed at strategic location in the building.
6. Temporary structure is erected in open space at ground level setback area which needs to be removed.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department, till such time running of factory is at your own risk & responsibility.

Yours faithfully

(Anil Garg)
Director
Ph: 011-23414000

Copy to:-

1. The Dy. Commissioner of Factory licensing, DMC 3rd, Floor, Civic Centre Minto Road, Delhi-110002