

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2023/GH/281

Dated:-13/06/2023

To

The Manager,
M/S Shree Lodge,
2012, Gali No. 7, Chuna Mandi,
Pahar Ganj, New Delhi.

Sub: **Regarding issuance of FSC in r/o M/S Shree Lodge at 2012, Gali No. 7, Chuna Mandi, Pahar Ganj, New Delhi.**

Sir,

This has reference to online ID No. **2023042707563** dated **27.04.23**, on the subject cited above. In this connection it is to inform you that the site was inspected by the officer concerned department on **05/06/2023** in the presence of **Manager** and following shortcomings were observed: -

1. First aid hose reel system found nonfunctional.
2. Fire pump found nonfunctional.
3. 04 no. rooms are shown at third floor in the building plan, whereas in application form same are not mentioned please clarify the same.

In view of above, Fire Safety Certificate (FSC) cannot be renewed. Therefore, you are requested to rectify the shortcomings at the earliest for further consideration in the matter.

Yours faithfully

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.