



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/EH/WZ/2023/ 315

Dated: 13/06/2023

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addep.lic-dl@nic.in

Subject: Regarding issuance of NOC from fire safety point of view in respect of Third Wave Coffee Pvt. Ltd. (A unit of Heisetasse Beverages Pvt. Ltd.) Located at North West Avenue Club Road, Punjabi Bagh, New Delhi-110026.

Sir,

Please refer to your online application no. 2023053009933 dated 30/05/2023 on the subject cited above. In this connection, it is to inform you that the premises was re inspected by officer concerned of this department on 06/06/2023 in the presence of Sh. Parteek (Manager) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above restaurant/eating house is running at Ground Floor in a Building comprised of Basement + Stilt + Ground + 03 Upper floors. Fire safety arrangements such as Fire Extinguishers, MOEFA etc provided. However the following shortcomings were observed.

1. Width of door size 1m x 2 is provided against requirement of 1.5m x 2.
2. First Aid Hose Reel is provided but not functional.
3. Main Fire Pump capacity of 450lpm is not provided.
4. Over Head water storage tank capacity of 20,000ltr is not provided.
5. Exit Signage's is not provided.
6. Smoke management system is not provided.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is not considered & rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Yours faithfully

(Atul Garg)
Director

Copy to: -

1. The Owner/Occupier, M/s Third Wave Coffee Pvt. Ltd. (A unit of Heisetasse Beverages Pvt. Ltd.) Located at North West Avenue Club Road, Punjabi Bagh, New Delhi-110026.
2. The DHO, MCD, West Zone, Shivaji Enclave, Raja Garden, New Delhi- 110027. (dhowest_zone@gmail.com).