

C/40

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,  
NEW DELHI

No. 16/DIS/MS/SZ/2023/ 1253

Dated: 16/06/2023

To,

Sh Ajay Khatri  
DGM - Fire & Safety,  
Indraprastha Gas Limited  
New Delhi

**Subject: Issuance of FSC in respect of CNG Station, Khasra No. 85/23 and 108/3, Vilage Bijwasan, Main Najafgarh Kapashera Road, New Delhi - 110061.**

Sir,

Please refer to your letter no. IGI/CNGPRJ/NOC/17042023 dated 17/04/2023 on the subject mentioned above. In this connection it is to inform you that the above said premise was inspected by officer of this department on 06/06/2023 in the presence of Mr Akash Malik (Manager) from fire safety point of view

During course of inspection the following shortcomings were observed

1. Portable gas detector (Hand held gas detector) found non functional it must be calibrated
2. MOEIA found nonfunctional
3. Water mist trolley found not provided.
4. All the electrical fitting must be laid through metal conduit & all electrical switch/ fitting / must be spark proof
5. The CNG pump found operational without getting Fire Safety Certificate from this department.

You are requested to comply above mentioned shortcomings under intimation to this department

Yours faithfully,

  
(Mr. Garg)  
Director,  
Delhi Fire Service

Copy to-

1. Sh Alok Sharma, Vice President-Fire & Safety IGI Bhawan, Plot No-4, Community Center, R K Puram Sec-9, New Delhi
2. Shri Arun Kumar Singh, Chairman, Fire & Safety IGI Bhawan, Plot No-4, Community Center, R K Puram Sec-9, New Delhi
3. The Manager, CNG Station, Khasra No. 85/23 and 108/3, Vilage Bijwasan, Main Najafgarh Kapashera Road, New Delhi - 110061