



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2023/ 1265

Dated: 19 .06.2023

To

Authorized Signatory, Mahesh C.G.H.S. Ltd. B-9, Vasundhara Enclave, Delhi-110092

Subject:- Regarding issuance of Fire Safety Certificate in r/o Mahesh C.G.H.S. Ltd. B-9, Vasundhara Enclave, Delhi-110092.

Sir.

This has reference to your letter no. Nil dated 29/05/2023 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officers concerned of this department on 02/06/2023 in the presence of Sh. Naresh Chandra and the following shortcomings were observed:-

- Hose Reel Hose provided but non functional.
- 2. Internal Hydrant provided but non functional.

Keeping in view of above shortcomings, the application for issuance of Fire Safety Certificate can not be considered at this stage. You are requested to rectify above mentioned shortcomings under intimation to this department for taking necessary action in this matter.

Yours faithfully,

DELHI FIRE SERVICE