



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/EH/WZ/2023/317

Dated: 16/06/2023

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
adlcp.lic-dl@nic.in

Subject: Regarding renewal of NOC from fire safety point of view in respect of Punjabi
Zaika, Located at 359A, Ground Floor, Raja Park, Shakur Basti, New Delhi -
110034.

Sir,

Please refer to your online application no. 2023052009329 dated 20/05/2023 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 08/06/2023 in the presence of Sh. Arvind Singh to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above restaurant/eating house is running at Ground Floor, in a Building comprised of Ground + 03 Upper floors. Fire safety arrangements such as Fire Extinguishers, MOEFA etc provided. However the following shortcomings were observed.

1. Main Fire Pump capacity of 450lpm is provided but not on auto mode.
2. Exit Signage's is not provided.
3. During inspection, it has been observed that first & second floor is now using as banquet hall shall be closed.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is not considered & rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Yours faithfully,

(Atul Garg)
Director

Copy to: -

1. The Owner/Occupier, M/s. Punjabi Zaika, Located at North West Avenue Club Road, Punjabi Bagh, New Delhi-110026. Online application ID- 2023052009329 dated 20/05/2023
2. The DHO, MCD, West Zone, Shivaji Enclave, Raja Garden, New Delhi- 110027.
dhowestzone@gmail.com