

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/EH/2023/322

Dated: 20/06/2023

To,

Mrs. Kushma Devi,
House No.RZ-8A/1, 2nd floor,
Gali No.13, Plot No. 8-A, Kh No.188, Durga Park,
Delhi-110045.

Sub: Issue of FSC in r/o M/s ChandraBadani, Shop No. GA-09, Metro Walk, Rohini, Sector-10, Delhi-110085.

Sir,

This is in reference to your Online application No.2023052209377 dated 22.05.2023 received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 06.06.2023, in presence of **Sh. B. L. Raju (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. The width of door is 1.10 mtr against the required width of 1.50 mtr. And alternate door of 1.50 mtr is not provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR

Ph; 011-23414000

OL
CH

Copy to:

MHA Id- 2023052209377