



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/2023/EH/321
To

Dated 20/06/2023

The Joint Commissioner of Police/ Lic,
1st Floor, Licensing Unit, Police Station
Defence Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o located at G-16, B-Block, Vijay Nagar, Delhi- 110009.

Sir,

This has reference to online MHA Portal I.D. No. 2023060510295 Dated: 07.06.2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 14.06.2023 in the presence of Sh. Amar Chand (Chowkidar) to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection it has been observed that the building/ premise is comprised of basement, stilt, upper ground & 03 upper floors but (Restaurant proposed at upper ground floor & 03 upper floors only). Your request for FSC is rejected under Rule 35 (3) due to following shortcomings.

- 1 Fire check door not provided in basement & kitchen area.
- 2 Smoke ventilation system is not provided in basement and all upper floors.
- 3 Hose reel hose provided but not functional.
- 4 Automatic fire detection and alarming system provided but not functional.
- 5 MOEFA & talk back system not provided.
- 6 Public address system not provided.
- 7 Internal hydrants provided but not functional.
- 8 Ground level electrical driven fire pump capacity of 2280lpm., diesel engine pump 2280lpm & jockey pump 180lpm provided but not functional.
- 9 Terrace level firefighting pump capacity of 450lpm provided but not functional.
- 10 Exit signage and floor signage not provided in the building.
- 11 Standby power supply provided but not functional.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of restaurant is at your own risk & responsibility.

Yours faithfully


(Atul Garg)
Director
Ph: 011-23414000
E/C