



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2023/WZ/325

Dated: 20/06/2023

To,

The Principal,
MC Primary Girls School,
E-3, J.J. Colony, Bawana,
Delhi-110039.

Sub: - Regarding issuance of Fire Safety Certificate in r/o MC Primary Girls School, E-3, J.J. Colony, Bawana, Delhi-110039.

Madam,

This has reference to your letter no. nil dated 27.04.2023 received through outdoor diary no. 2199 dated 24.05.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by the officer concerned of this department on 02.06.2023 to see the compliance of the requisite fire safety measures. Sh. Ravinder Rana (Teacher) was present at the time of inspection.

During the course of inspection it was observed that school building was comprised of Two Blocks- Ground floor plus two upper floors & Ground plus three upper floors interconnected. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. There is only 01 continuous staircase up to the terrace against the required 02 continuous staircases up to the terrace.
2. First-Aid Hose Reels provided but nozzle found missing.
3. Terrace level fire pump of 450 lpm capacity provided but could not be tested due to non availability of three phase electricity supply.
4. Over Head tank of 1000 ltrs capacity is provided against the requirement of 10,000 ltrs capacity.
5. Exit Signage's not provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully,

(Ajul Gang)
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, MCD, Civic Center, New Delhi.