



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2023/NDZ/328

Dated 20/06/2023

To,

The Ex. Engineer (Elect.)-II  
EDMC Office of the Executive Engineer (Elect.)-II/SSZ  
MCD 2<sup>nd</sup> Floor, Technical Laboratory, Near NH-24  
Gazipur, Delhi-110096

**Subject:** - Regarding Issuance of Fire Safety Certificate in r/o MCD Primary School at Chand Mohila, Gandhi Nagar, Delhi-110031.

Sir,

This is in reference to your letter No. EE(Elect.)-II/SHN(S)/2023-24/D-18 dated 17/04/2023 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view on dated 25/05/2023 in presence of Mrs. Menu Puri, In-charge of the School. The building comprised of ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. One staircase of width 1.30 meter is provided against requirement of two staircase of width 1.50 meter.
2. Overhead water storage tank capacity 5000 liters is provided against requirement of 10,000 liters.
3. Exits signage not provided.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, MCD  
15<sup>th</sup> Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg,  
New Delhi-110002
2. MCD Primary School  
Chand Mohila Gandhi Nagar, Delhi-110031.