

C-17

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/School/NDZ/2023/320

Dated: 20/06/2023

To

The Principal,  
Sri Guru Teg Bahadur Khalsa Girls Sr. Secondary School,  
Sis Ganj, Chandni Chowk, Delhi- 06.

**Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o Sri Guru Teg Bahadur Khalsa Girls Senior Secondary School, SIS Ganj, Chandni Chowk, Delhi - 06.**

Sir,

This has reference to your letter no. SGTB/2023/F-6/5095 dated 29.05.2023 on the subject cited above. In this connection it is to inform you that officer concerned of this department visited the school/ premises on 07.06.2023 in the presence of Principal and observed that the school building is comprised of Basement + ground + 03 upper floors and have been partially complied the shortcomings issued vide letter no. F6/DFS/MS/2018/1403 dated 05.04.2018 except following which still exists:-

1. One additional staircase to be provided in the rear side to meet the travel distance.
2. Sprinklers to be provided in basement.
3. Fire Pumps capacity of 2 x 450 LPM not provided.
4. Overhead water tank capacity of 15,000 liter not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)  
Director

Delhi Fire Service  
Tel: 011-23414000

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.

16/6