

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F-6/DFS/MS/EH/2023/SZ/324

Dated 20/06/2023

To
The Dy Health Officer, SDMC
Public Health Officer,
Aurobindo Marg, South Zone,
Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o **M/s YOU MEE** (A Unit of Lite Bite Foods Pvt Ltd) at R-04A, Upper Ground Floor, Epicuria TDI South Bridge, Nehru place Metro Station, New Delhi 110019

Sir,

This has reference to with MHA Portal ID 2023052209383 dated 22/05/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 02/06/2023 in the presence of Mr. Pralay to verify the fire safety measures installed in the building and observed that restaurant running at upper ground floor only. During inspection, following points were observed

1. There are two exit door having width of 1.50 mtr & 1.0 mtr against the required width of 1.50 mtr each respectively at ground floor. The second exit door is also passing through kitchen and it is not acceptable as per the provision contained in UBBL -2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to -

1. The Joint Commissioner of Police, Lic/Branch, 1st Floor, P S Defence Colony, New Delhi -110049. For taking necessary action on the matter