



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/2023/EH/328
To

Dated 23/06/2023

The Joint Commissioner of Police/ Lic,
1st Floor, Licensing Unit, Police Station
Defence Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Barbeque Nation (A Unit of Ms Barbeque Nation Hospitality Ltd.) located at 3rd Floors, B-2, Gujrawala Town, Part-1, Delhi-110009.

Sir,

This has reference to online MHA Portal I.D. No. 2023060610349 dated 08.06.2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 14.06.2023 in the presence of Mr. Bijender (Manager) to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection it has observed that the building/premise is comprised of basement, ground & 03 upper floors but (Restaurant is purposed at 3rd floor only). Your request for FSC is rejected under Rule 35 (3) due to following shortcomings.

- 1 Smoke ventilation system is not provided at third floor.
- 2 Diesel Engine Pump capacity of 2280lpm not provided.
- 3 Terrace level fire water tank capacity of 1,00,000ltr being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.
- 4 Exit signage's not provided at strategic location in the restaurant.
- 5 Standby power supply not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of restaurant is at your own risk & responsibility.

Yours faithfully


(Atul Garg)
Director
Ph: 011-23414000
dc f