

HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 2023/286

Dated: 20/06/2023

To,

The Manager,
Blue Pearl Guest House,
8653- 8664, Arakashan Road,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S **Blue Pearl Guest House** located at 8653-8664, Arakashan Road, Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2021020210093 dated 02/06/2023, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 08/06/2023 in the presence of **Manager** and following shortcomings were observed:

1. Fire Check doors and Smoke management system are not installed as per Gazette Notification dated 27.05.2019.
2. Hose reel is not provided in basement.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcomings for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.