

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/2023/SZ/1303

Dated 22/06/2023

To

The Authorised Signatory,
M/s Fashion Trendz,
S-40 Okhla Industrial Area,
Phase-II, New Delhi 110020

Sub.- Regarding grant of Fire Safety Certificate in r/o M/s Fashion Trendz at S-40 Okhla Industrial Area, Phase-II, New Delhi 110020

Sir,

This has reference to your letter received through outdoor diary no 2382 Dated 30/05/2023 on the subject above. In this connection, it is to inform you that the officer concerned of this department and observed the aforesaid building in presence of Mr. Vikas (HR) on 19/06/2023 to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed

- 1 Fire check door not provided in building as approved by this department.
- 2 Overhead tank capacity 10,000 ltrs found provided against the required capacity 20,000 ltrs.
- 3 Standby Diesel engine operated fire fighting pump capacity 2280 LPM not provided
- 4 Exit signage's found removed at some locations.
- 5 Temporary structure seen at terrace levels, which need to be removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(AT/DGARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to -

1. The Executive Engineer (Bldg) SDMC Jal Vihar, Lajpat Nagar, New Delhi 110024