

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F 6/DFS/MS/GH/2023/SZ/ 300

Dated: 26/06/2023

To

The Addl. Commissioner of Police (Lic.),  
1st Floor, P.S. Defence Colony,  
New Delhi-110049.

Sub: Issuance of NOC in r/o M/s Hotel Paradise International at Plot No A-272, NH-8,  
Mahipalpur New Delhi 110037

Sir,

This is in reference with MHA Portal ID 202302/201872 dated 12/02/2023 the subject cited above. In this connection, it is to inform you that the premise have been inspected by officer concerned of this department on 15/06/2023 and observed that the Guest House is running in Basement (Parking) Ground plus Three Upper Floors. During the course of inspection, the following shortcoming observed were noticed -

1. Carbon Monoxide detector not provided as per clause 7.31 of UBBL-2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

- 1 M/s Hotel Paradise International at Plot No A-272, NH-8, Mahipalpur New Delhi 110037