

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

Dated: 23/06/2023

No.F.6/DFS/MS/EH/2023/SZ/ 337

To,

The Manager  
M/s Jubilant Foodworks Ltd (Domino's Pizza),  
Upper ground, BF-4, Janakpuri, Jail Road, New Delhi-110058.

**Sub:** - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s Jubilant Foodworks Ltd. ( Domino's Pizza) at Upper ground, BF-4, Janakpuri, Jail Road, New Delhi-110058.

Sir,

Please refer to your online ID No. 2023060710435 Dated 07/06/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the premises to verify the fire safety arrangements in accordance with the Delhi Fire Service Act, 2007 and Rules 2010. At the time of inspection Sh. Rahul Kumar (Branch Manager) was present and it was observed that the eating house is running at upper ground floor only and have following shortcomings:-

1. Second exits having width 1.5 m not provided.
2. First aid hose reel not provided.
3. MOEFA not provided.
4. Down/comer system not provided.
5. Terrace pump having 450 lpm output 40 m head not provided.
6. Overhead water storage tank capacity of 20,000 liters not provided.
7. Exit signages are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully

(Aul Garg)  
Director  
Delhi Fire Service

okps

Copy to:-

The Joint Commissioner of Police,  
Licensing Unit, Office of the Joint Commissioner of Police ,  
1<sup>st</sup> Floor, Police Station, Defence Colony, New Delhi.