

e-313
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2023/HTL/22

Dated: 27/06/2023

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/S Maiden Hotel located at 07, Shamnath Marg, Civil Lines, Delhi.

Sir,

This has reference to email dated 13.06.2023 on the subject cited above. It is to inform you that the building was inspected by the officer concerned from this department on 16.06.2023 in the presence Mr. Jaylal (Chief Engg.) and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. MOEFA with alarm system provided but not functional.
2. Fire pump not in auto start mode.
3. H.T. & L.T. panels are not protected with gas based total flooding system.
4. Transformers (oil filled) are not protected with foam based trolley system.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

Copy to:-

The Manager, M/S Maiden Hotel at 07, Shamnath Marg, Civil Lines, Delhi.

W
27/6