

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2023/299

Dated: 26/06/2023

To

The Manager,  
M/s M.D. International,  
3621-A, Dariba Pan, Pahar Ganj,  
New Delhi.

**Subject:- Request for renewal of FSC r/o M.D. International, 3621-A, Dariba Pan, Pahar Ganj, New Delhi.**

Sir,

This has reference to your online id. no. 2023061010609 dated 10.06.23 on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 16/06/23 in presence of Mr. Anand, Manager and following shortcomings were observed:

1. Hose reel is not provided at each floor (1<sup>st</sup> and 3<sup>rd</sup> floor).
2. Smoke management is not installed as per gazette notification 27.05.19.

In view of above, FSC cannot be renewed. Therefore you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,

(Atul Garg)  
DIRECTOR  
Ph. No. 011-23414000

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.