



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2023/WZ/329

Dated: 26/06/2023

To,

The Principal,
Parvati Modern Public School,
Main Saboli Road, Rajeev Colony,
Narela, Delhi-110040.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Parvati Modern Public School,
Main Saboli Road, Rajeev Colony, Narela, Delhi-110040.

Sir,

This has reference to your letter no. nil received via outdoor diary no. 2226 dated 25.05.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by the officer concerned of this department on 02.06.2023 to see the compliance of the requisite fire safety measures. Smt. Parwati Tiwari was present at the time of inspection.

During the course of inspection it was observed that school building comprised of Two Blocks of Ground Floor only. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. Door width provided 1 m against the required width of 1.20 m.
2. Fire Extinguishers provided but not functional.
3. Building plans on a scale of 1:100 duly signed by registered architect and the owner not provided.

You are advised to rectify the above-mentioned shortcoming under intimation to this department.

Yours Faithfully


(Anil Bhardwaj)
Director
Ph. 011-23414000


Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.