



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

75  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/EH/WZ/2023/326

Dated: 23 / 06 / 2023

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[addlcp.lic-dl@nic.in](mailto:addlcp.lic-dl@nic.in)

Subject: **Regarding issuance of NOC from fire safety point of view in respect of The Rider Club Lounge Bar (A Unit of Dazy Night Club Pvt. Ltd.), Located at TDI Paragon Mall, Shop No. 15, 16 Ground Floor, Near Delhi Police Station, Rajouri Garden, New Delhi – 110027.**

Sir,

This is reference to your online application ID No. 2023060610363 dated 06.06.2023 received through MHA Portal, on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 16/06/2023 in the presence of Sh. Kishor Chand Joshi to check the functioning of fire safety arrangements provided in the building.

During inspection, it has been observed that the said restaurant is running at Ground Floor in TDI Paragon Mall is comprised of Lower Basement, Upper Basement, Ground + 03 upper floors was issued FSC vide letter no. F.6/DFS/MS/WZ/2022/570 dated 15/12/2022. Fire Safety arrangements such as Fire Extinguishers, First-Aid Hose Reel, Pumping Arrangements, Internal Hydrant, overhead water storage tank etc. have been provided in the building. However, the following shortcomings were observed.

1. Smoke Management system is not provided.
2. Automatic fire detection and alarming system is not provided.
3. MOEFA is not provided.
4. Exit Signage is not provided.
5. Hydrant & hose reel hose is provided in mall but not accessible for the restaurant.

In view of above Shortcomings the application for issuance of Fire safety Certificate is not considered and rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The license issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire Safety arrangements.

Yours faithfully,

  
(Atul Garg)  
Director

Copy To:-

1. The Owner/Occupier, M/s. The Rider Club Lounge Bar (A Unit of Dazy Night Club Pvt. Ltd.), Located at TDI Paragon Mall, Shop No. 15, 16 Ground Floor, Near Delhi Police Station, Rajouri Garden, New Delhi – 110027. Online ID:- 2023060610363 dated 06.06.2023
2. The DHO, West Zone, MCD, Shivaji Enclave, Raja Garden, New Delhi- 110027.