



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2023/WZ/330

Dated: 26/06/2023

To,

The Principal,  
Sant Gyaneshwar Model School,  
Lakhmi Enclave, Extended Lal Dora,  
Alipur, Delhi-110036.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Sant Gyaneshwar Model School, Lakhmi Enclave, Extended Lal Dora, Alipur, Delhi-110036.

Sir,

This has reference to your letter no. SGMS/Office/023 dated 21/04/2023 received via outdoor diary no. 2109 dated 22.05.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 02.06.2023 to see the compliance of the requisite fire safety measures. Sh. Prem Singh Mann was present at the time of inspection. During the course of inspection it was observed that previously this department had issued FSC for a building of Ground plus two upper floors vide letter no. F6/DFS/MS/School/2012/890 dated 12/03/2012 but now the school building found comprised of two blocks interconnected of Ground plus two upper floors & ground plus three upper floors. Your request for issuance of FSC is rejected as the following shortcomings were observed:-

1. Gate width found 3 m against required width of 4.5 m.
2. Width of staircase of new block found 1.40 m & 1.35 m against the required width of 1.50 m each.
3. In new block no staircase reaches up to terrace against required 02 no. of continuous staircase up to terrace.
4. First Aid Hose Reels provided but not functional in old block and First Aid Hose reels not provided in new block.
5. P.A system not provided.
6. Terrace level pump of 450 lpm capacity not provided.
7. An overhead tank of 1,000 ltrs capacity provided against the requirement of 10,000 ltrs capacity.
8. Exit signage's not provided.
9. Building plans on a scale of 1:100 duly signed by registered architect and the owner not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)

Director

Ph. 011-23414000

our

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.