

C-127 DFA/FT

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/EH/2023/SZ/ 156
To,

Dated: 23/6/2023

The Manager,
M/s SHER E DIL Restaurant,
B-7, (GF) Shankar Garden, Main Najafgarh Road,
VikasPuri, New Delhi-110018.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s SHER E DIL Restaurant at B-7, (GF) Shankar Garden, Main Najafgarh Road, VikasPuri, New Delhi-110018.
Sir,

Please refer to your letter ID No. 2023052209389 dated. 10/06/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Mr. Sanjeev Sharma (Manager) was present and it was observed that the building is comprised of basement, ground plus three upper floors but restaurant at ground floor only and have following shortcomings:-

1. Exits are blocked by store material & sofa.
2. First aid hose reel provided but not functional.
3. MOEFA provided but not functional.
4. Down comer system provided but not functional.
5. Fire pump provided but not functional at terrace & auto mode.
6. Overhead water tank 10,000 liters provided in place of 20,000 liters.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully


Anil Garg)
Director
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police, 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi-110064 (With a request to take further action as restaurant does not have fire NOC)