

968

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Dated:- 03/06/2023

No.F6/DFS/MS/EHNDZ/332

To,
The Manager,
M/S Tashan bar & Lounge,
80 A, 400-401-402/27-28 3244,
Krishna market, Pahar Ganj, New Delhi.

Sub: Regarding renewal of FSC in r/o M/S M/S Tashan bar & Lounge , 80 A,400-401-402/27-28 3244, Krishna market , Pahar Ganj, New Delhi.(Online id. 2023060810499 dated 09/06/2023).

Sir,

This has reference to Online id. no. 2023060810499 dated 09/06/2023, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 19.06.23 in presence of **Manager** and following shortcomings were observed:

1. Hose reel & hydrant found nonfunctional.
 2. Overhead tank of 20,000liter and pump found removed.
- Further, building Plan is not signed by owner/occupier himself.

In view of above, FSC cannot be renewed. Therefore you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.