

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2023/ 1320

DATED: 27/06/2023

To,

The President / Secretary
EPDP CGHS Ltd.
Plot No-19, Sector-04, Dwarka,
New Delhi-110078

Subject: - Complaint of fire fighting equipments in r/o EPDP CGHS Ltd. Located at Plot No-19, Sector-04, Dwarka, New Delhi-110078

Sir,

Please refer to Email dated-12/06/2023 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 15/06/2023 in the presence of Sh. P.K Ghosh (Joint Sec.) for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Six meter wide internal road around the building found blocked/encroached
2. Staircases must be kept free from any obstruction & must not be locked at terrace
3. Hose Reels & Hydrants system found nonfunctional.
4. Sprinkler system in basement found nonfunctional
5. All the Pumps at ground level found nonfunctional.
6. Terrace fire water tank of 10000 ltrs capacity must be connected with hydrant line.
7. Exit signage's found removed at some places.

The FSC issued vide letter No. F6/DFS/MS/CGHS/2019/SZ/437, dated 26/02/2019 shall be remain suspended till the compliance of above shortcoming.

In view of the above, you are directed to comply all the shortcomings within 90 days otherwise action shall be taken against you under Delhi Fire Service Act 2007 & Rule 2010.

Yours faithfully,


V.K. Garg
(Director)
Delhi Fire Service

Copy to -

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi
2. Sh. B.K. Jana EPDP CGHS Ltd. Located at Plot No-19, Sector-04, Dwarka, New Delhi-110078