



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/6
आज्जादी का
अमृत महीना

DFB/FFI

No. F6 /DFS/MS/Industrial/SZ/2023/1330

Dated: 28/06/2023

To,

The Authorized Signatory,
Plot no. D-81, Okhla Industrial Area Phase-I,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Frontier Autoworld Pvt. Ltd.,
Plot no. D-81, Okhla Industrial Area Phase-I, New Delhi.

Sir,

This has reference to the your letter no. nil dated 01.06.2023 on the subject cited above, it is informed that the said building was inspected by a team of officers concerned of this department on 21.06.2023 in the presence of Mrs. Dipti Sharma (Manager) and it was observed that the building is comprised of Basements + Stilt + Ground + 02 upper floors. During the inspection following shortcomings were observed:

1. Fire check door (FCD) found not installed properly.
2. Vertical openings found not sealed.
3. No ventilation provision in basement.
4. Hose reels, Internal & Yard hydrant found non functional.
5. Automatic Sprinkler System found non functional.
6. All fire pumps at terrace & ground level found non functional.
7. Water curtain not provided in car lift.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Aul Garg)

Director

Delhi Fire Service

28/06/23 M01

Copy to:-

1. The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.