



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/GH/SZ/2023/303

Dated: 27/06.2023

To

The Deputy Commissioner (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi.

Subject:- Online Application ID No. - 2023042907772 in r/o **The Saga Hotel, A unit of Todoslosantos Global Pvt. Ltd.** situated at Shop no. 4&5, Green Park Main, New Delhi-110016.

Sir,

This has a reference to online application ID No.- 2023042907772 dated 08.06.2023 received on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 23.06.2023 in the presence of Mr. Zahiruddin (GM) and observed that building comprised of Basement+Ground + 03 upper floors and following shortcomings were observed during inspection :

1. Carbon monoxide detector not provided.
2. Fire check door have gaps and not provided in basement.
3. Hose reel & Hydrant not provided in basement.
4. Exit Signage not provided.

In addition to above the application needs correction in respect of total number of rooms, total number of staircase, width of staircase. Accordingly, the applicant may be directed to furnish correct information and compliance of above shortcomings for further necessary action for issuance of Fire Safety Certificate.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

The Manager,
The Sage Hotel, A unit of Todoslosantos Global Pvt. Ltd.
Shop no. 4 & 5, Green Park Main, New Delhi-110016.

new of ✓