



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

C117  
27/06/2023

No. F6/DFS/MSEH/WZ/2023/343

Dated. 27/06/2023

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
addlep.lc-dl@nic.in

Subject **Regarding renewal of NOC from fire safety point of view in respect of White and Black Hospitality Private Limited Located at Property No. 11-C, 2<sup>nd</sup> & 3<sup>rd</sup> floor, Club Road, Punjabi Bagh, New Delhi-110026.**

Sir,

This is reference to your online application ID No. 2023011000322 dated 09/06/2023 received through MHA Portal, on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 16/06/2023 in the presence of Sh. Salim Khan to check the functioning of fire safety arrangements provided in the building.

During inspection, it has been observed that the said restaurant is running at 2<sup>nd</sup> & 3<sup>rd</sup> Floor in a building comprised of Basement + Stilt + Ground + 03 upper floors, earlier FSC was issued by this department vide letter No. F.6/DFS/MS/2020/EH/98 dated 02/07/2020 namely Night Walk (A unit of BS Hospitality). Fire Safety arrangements such as Fire Extinguishers, first-Aid Hose Reel, Pumping arrangements & Internal Hydrant etc. have been provided in the building. However, the following shortcomings were observed.

1. Smoke Management system is found removed.
2. First-Aid Hose Reels is provided but not functional.
3. Automatic fire detection and alarming system is provided but not functional
4. MOEFA is provided but not functional.
5. Exit Signage is not provided
6. Internal Hydrant is provided but not functional
7. Fire fighting pumps are provided but they are not on auto mode.
8. Overhead water storage tank capacity of 10,000 ltr is found removed.
9. Roller in iron staircase is again provided. However, staircase shall remain fixed

In view of above Shortcomings, the application for renewal of Fire Safety Certificate is not considered and rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The license issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire Safety arrangements.

Yours faithfully,

(Sd/-) Garg  
Director

Copy To -

1. The Owner/Occupier, M/s. White and Black Hospitality Private Limited Located at Property No. 11-C, 2<sup>nd</sup> & 3<sup>rd</sup> floor, Club Road, Punjabi Bagh, New Delhi-110026. Online ID:- 2023011000322 dated 09/06/2023
2. The DHO, West Zone, MCD, Shivaji Enclave, Raja Garden, New Delhi- 110027

22/6/2023