

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/GH/2023/298

Dated 26/06/2023

To
The Joint Commissioner of Police / Lic-Branch
1st floor, Police Station,
Defence Colony, New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s CABANA HOTEL (A unit of Shree Prema) R-23, Greater Kailash-I New Delhi- 110048


Sir,

This has reference with MHA Portal ID No 2023060310196 dated 03/06/2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22/06/2023 in the presence of Mr Uday (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

- 1 Smoke Ventilation system not provided as per clause 7.31 of UBBL 2016.
- 2 First aid hose reel provided but found not functional.
- 3 Carbon Monoxide detector provided but found not functional.
- 4 Automatic sprinkler system provided but found not functional.
- 5 Fire fighting pumps provided but found not functional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully



(SUDHAR) 2
DIRECTOR
DELHI FIRE SERVICE

M. A.