



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F.6/DFS/MS/EH/SZ/2023/347

Dated: 28.06.2023

To

The Deputy Commissioner (Licensing)  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

Subject:- Online Application ID No.- 2023051609035 in r/o **Dominos Pizza Jubilant foodworks Limited** situated at Shop no. S-27, GF, Main Green Park Market, New Delhi-110016.

Sir,

This has a reference to online application ID No.- 2023051609035 dated 17.05.2023 received on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 23.06.2023 in the presence of Mr. Rakha Parshad (Manager) and observed that building comprised of Basement + Ground + 03 upper floors and restaurant is running at ground floor only and following shortcomings were observed during inspection :

1. Back door of width 1.5 mtr. is not provided.
2. Hose reel is not provided.
3. MOEFA is not provided.
4. Fire pump capacity of 450 LPM not provided.
5. Overhead water tank capacity of 20,000 liters not provided.
6. Exit Signage not provided.

In addition to above the application needs correction in respect of total number of staircase, width of staircase. Accordingly, the applicant may be directed to furnish correct information and compliance of above shortcomings for further necessary action for issuance of Fire Safety Certificate.

Yours faithfully,

  
(Atul Garg)  
Director,  
Delhi Fire Service

Copy to:-

The Manager,  
Dominos Pizza Jubilant foodworks Limited,  
Shop no. S-27, GF, Main Green Park Market, New Delhi-110016.