

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2023/SZ/363

Dated:- 04/07/2023

To

The Dy. Health Officer, (MCD)
Public Health Officer, (Green Park Zone)
Aurobindo Marg, Green Park, Delhi 110016.

Sub: - Regarding issuance of fire safety certificate in r/o M/s CABO DEIL (Unit of Alley house Kitchen and Bar Pvt Ltd, Located at Plot No 192, Ground Floor, Carrippa Marg, Khirki Extn. Gate No 2, New Delhi 110062.

Sir,

This has reference to with MHA Portal No. 2023061410829 dated 14/06/2023, 2023061210691 dated 12/06/2023 & 2023051208807 dated 30/05/2023 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 26.06.2023 in the presence of Mr. Prithvi (Supervisor) to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. The exit doors having width of 1.50 mtr & 1.20 mtr wide provided against the required width of 1.50 mtr each.
2. Terrace level fire fighting pumps capacity 450 LPM not provided.
3. Overhead tank capacity 2,000 ltrs provided against the required capacity of 20,000 ltrs.
4. Exit Signage not provided.

Keeping in view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE