

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2023/SZ/ 358

Dated: 04/07/2023

To

The Dy. Health Officer, (MCD)
Public Health Officer, (Green Park Zone)
Aurobindo Marg, Green Park, Delhi 110016.

Sub: - Regarding issuance of fire safety certificate in r/o M/s CHUNGWA (Unit of Super Caterers)
located at M-34, Market, Greater Kailash II, New Delhi 110048

Sir,

This has reference to with MHA Portal No. 2023042407234 dated 03/05/2023 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 26.06.2023 in the presence of Mr. J. D Baniwal to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. Automatic sprinkler system provided but found not functional.
2. Internal hydrant provided but found not functional.
3. Terrace level fire fighting pumps capacity provided but found not functional.
4. Exit Signage found removed at some places.

Keeping in view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

