

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2023/364

Dated:-04/07/2023

To
The Manager
M/S Coffee Day Global Ltd,
Shop No. 44, Janpath, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Coffee Day Global Ltd, Shop No. 44, Janpath, New Delhi.

Sir,
This has reference to online ID No. 2023061510936 dated 15.06.23, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 27/06/2023 in the presence of Mr. Kamal and following shortcomings were observed:-

1. 02 Staircases of 1.5 each are not provided
2. 02 Exits of 1.5 meter each are not provided.
3. First aid hose reel and hydrant systems are not provided.
4. Terrace pump of 450 LPM is not provided.
5. Overhead fire water tank of 20,000liter capacity is not provided.
6. Further, building plan as uploaded does not have area details, exit & staircase location, signature of owner & architect.

In view of above, the case is rejected. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.