



C-22

7
आजादी का
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2023/342

Dated: 03/07/2023

To,

The Principal,
M.C. Primary School,
Devaram Park, Tri Nagar,
New Delhi-110035.

Sub: - Regarding Issuance of fire safety certificate in r/o M.C. Primary School, Located at Devaram Park, Tri Nagar, New Delhi-110035.

Sir,

Please refer to your Outdoor Diary No.-2133 dated 22/05/2023, on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 14/06/2023 in presence of Smt. Usha (Principal) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the said school is comprised of Ground + 02 Upper Floors. Fire safety arrangements Such as Fire Extinguishers, First -Aid Hose reels, Terrace pump, Over head water storage tank, etc. are provided. However the following Shortcomings were observed.

1. First Aid Hose Reels are provided but not functional.
2. Terrace level pump capacity of 220 lpm is provided but not functional.
3. Overhead water storage tank of capacity 2500 ltrs is provided but not exclusively for fire fighting purpose.

In view of above Shortcomings, the application for Issuance of Fire safety Certificate is not considered & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. Statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

2/c JH
27/6/2023