



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

75
आजादी का
अमृत महोत्सव

Dated: 03/07/2023

No: F.6/DFS/MS/School/2023/WZ/340

To,

The Principal,
Modern Little Angel Public School,
Kh. No. 154, Ganga Toli Road,
Village, Pooth Khurd, Delhi-39.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Modern Little Angel Public School,
Kh. No. 154, Ganga Toli Road, Village, Pooth Khurd, Delhi-39.

Madam,

This has reference to your letter no. 03 nil received via outdoor diary no. 2227 dated 25.05.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by the officer concerned of this department on 20.06.2023 to see the compliance of the requisite fire safety measures. Smt. Suman Kumari was present at the time of inspection.

During the course of inspection it was observed that school building comprised of Ground Floor only. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. Door width provided 0.90 m against the required width of 1.20 m.
2. Fire Extinguishers not provided.
3. Building plans on a scale of 1:100 duly signed by registered architect and the owner not provided.

You are advised to rectify the above-mentioned shortcoming under intimation to this department.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

Atul Garg

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.