

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2023/SZ/359

Dated: 04/07/2023

To
The Dy. Health Officer, (MCD)
Public Health Officer, (Green Park Zone)
Aurobindo Marg, Green Park, Delhi 110016.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Shree Bhagatrams located at Ground floor, Shop No 3 & 4, Vasant Square Mall, Vasant Kunj, New Delhi-110070

Sir,

This has reference to with MHA Portal ID 2023061310783 dated 14/06/2023 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 26.06.2023 in the presence of Mr. Gautam Khanna to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. There is one exit door having width of 2.0 mtr provided against the required 02 exit having width of 2mtr & 1.50 mtr.

Keeping in view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATEL GARG)
DIRECTOR
DELHI FIRE SERVICE

Om m