

c/a

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 317

Dated:-24.07.2023

To,  
The Manager  
M/S Tourist Lodge Guest House,  
26, Arakashan Road,  
Pahar Ganj, New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o Tourist Lodge Guest House at 26, Arakashan Road, Pahar Ganj, New Delhi.**

Sir,

This has reference to on line ID No. 2023062011206 dated 20/06/2023, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 27/06/2023 in the presence of Ms. Siffy and following shortcomings were observed: -

1. Smoke management system is not provided as per Gazette Notification dated 27.05.2019
2. Fire Check Door on the staircase are not provided as per Gazette 27.05.2019
3. CO type detectors found nonfunctional.

Hence, Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police( lic), 1st floor, Defence Colony Police Station, New Delhi.