

C-105

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001**

No. F6/DFS/MS/GH/2023/SZ/ 316

Dated: 07/07/2023

To,

The Addl. Commissioner of Police,
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi-110064.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s Vicky Guest House, C-222, Mayapuri Phase II, New Delhi -110064.

Sir,

Please refer to your letter ID No. 2023050808382 dated 18/05/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Upneet Singh (Owner) was present and it was observed that the guest house running at first & second floor only and have following shortcomings:-

1. Fire check doors & Carbon monoxide detection system not provided as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. M/s Vicky Guest House, C-222, Mayapuri Phase II, New Delhi-110064.