

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6 /DFS/MS/EH/2023/SZ/ 1384

Dated: 06/07/2023

To

Authorized Signatory,
M/s Guman House & Ompro Tower,
65-A, Kalu Sarai, New Delhi – 110016.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Guman House & Ompro Tower,
65-A, Kalu Sarai, New Delhi – 110016.

Sir,

This has reference to email dated 24/06/2023 on the subject cited above. In this regard it is to inform you that FSC under Rule 35 of Delhi Fire Service Rules-2010 is issued only for those premise which are referred by building Authority/local authority as specified in section 2 (q) of DFS Act 2007 to this department.

In this regard you are advised to first apply with concern building sanctioning authority with a request to forward following documents to this department to ensure proper implementation of fire prevention & fire safety measures as applicable under Rule 33 of DFS-2010 the said premise/building.

1. Sanctioned/ Completion plans.
2. As built plan through building/local Authority, if sanctioned/Completion plans are not available.
3. Initial date of operation of Occupancy in this building.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Bldg) MCD, Aurobindo Marg, Green Park, New Delhi 110016.