



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No: F.6/DFS/MS/WZ/2023/ 1400

Dated: 07/07/2023

To

Sh. Ajay Bindal (Authorised Signatory),
M/s. Aggarwal Prestige Mall,
Plot No. 02, Community Centre,
Adjoining Road No. 44, Pitampura,
(Rani Bagh), New Delhi.

Sub.: Regarding renewal of Fire Safety Certificate in r/o M/s. Aggarwal Prestige Mall located at Plot No. 02, Community Centre, Adjoining Road No. 44, Pitampura (Ranibagh), New Delhi.

Sir,

This is in reference to your letter No. USHPL/AS/APM/DFS/2K23/360 dated 16.05.2023 on the subject cited above. In this connection, it is to inform you that the building was inspected by the officer concerned of this department in the presence of Sh. Ajay Bindal, on 03.07.2023 to check the status of the fire safety arrangements already provided in the building.


During the course of inspection, it was observed that the building is comprised of Basement, lower ground, upper ground plus five upper floors. Fire safety arrangements such as fire extinguishers, hose reel hose, MOEFA, Detection and alarming system, Sprinkler System, wet riser cum down comer, PA system, fire pumps, underground water tank capacity 2,00,000 lts, overhead water storage tank capacity 10,000 lts etc. found provided. However, following shortcomings were observed: -

1. Detection system found removed at some places.
2. Pressurization in lift lobby found removed.
3. Door closer of Fire Check Doors found broken/non-functional.
4. Exit signages found removed at some places.

In view of the above shortcomings, the request for renewal of fire safety certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department for further necessary action in this regard.

Yours faithfully


(Atul Garg)
Director


06/07/23