

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/CGHS/2023/ 1398

Dated 07/07/2023

To,

The President,  
Gayatri CGHS Ltd.  
Plot No. 09, Sector - 09, Dwarka,  
New Delhi - 110075

Subject: Renewal of Fire Safety Certificate in r/o Gayatri CGHS Ltd. Located at Plot No. 09, Sector - 09, Dwarka, New Delhi - 110075.

Sir,

This is in reference to your letter No. GCGHS/SECY/DFS/2023/1860, nil on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 30/06/2023 in presence of Sh. Kamal (Society representative) from fire safety point of view.

During course of inspection the following shortcomings are observed.

1. Trimming of trees/ encroachment must be removed to ensure free movement of fire vehicles around the building.
2. Hoses & branches found missing at some places.
3. Terrace pump found nonfunctional in auto mode.
4. Exit signage found removed at some places.
5. Dully filled form J & K are not submitted.

You are requested to comply the abovementioned shortcomings under intimation with this department.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service  
ok  
10/7/23

Copy to; - The Joint Director, DDA, Vikas Sadan, INA, New Delhi.