

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No. F6/DFS/MS/NDZ/2023/ 1403

Dated:- 07/07/2023

To,

The Assistant Engineer,  
PWD, Health maintenance Electric Sub Division (Central),  
GIPMER, GB Pant Hospital New Delhi.

**Sub:- Inspection of all major hospitals from fire safety point of view.**

This has reference to the directions issued by the Chief Secretary, Govt. of NCT of Delhi on the subject cited above. In this regard, it is to inform you that the 02 blocks of GB Pant hospital were inspected by the officers concerned of this department on 27.06.2023 in the presence of Sh. Nand Lal Gupta AE (E) & Sh. Amit Kumar JE (E), PWD and the following shortcomings were still not complied.

**A Block:-**

1. 02 staircases found blocked by dumping of waste materials.
2. Corridor found encroached which create an obstacle to free movement of Occupants/patients.
3. Detection system found nonfunctional.
4. Smoke management system is not provided at upper floors.
5. Hose boxes found removed at some places.
6. Lift signages are not provided.

**D Block (EDP Cell):-**

1. Temporary structures are erected at ground and upper floors, which create obstruction in means of egress.
2. Fire check door found broken at some floors, required to be repaired.
3. Pressurization in lift lobby & shaft found nonfunctional.

Therefore you are requested to rectify the above shortcoming immediately. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier. The statutory authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)  
DIRECTOR

Delhi Fire Service

**Copy to:-**

1. The Medical Superintendent, G.B. Pant Hospital, New Delhi.
2. The Medical Director, GIPMER, G.B. Pant Hospital, New Delhi.
3. CMO, Nodal Officer, PWD, GIPMER, G.B. Pant Hospital, New Delhi.
4. The Executive Engineer, G.B. Pant Hospital, New Delhi.