

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/2023/EH/ 3 66

Dated 06 /07/2023

To

The Joint Commissioner of Police/ Lic, 1st Floor, Licensing Unit, Police Station Defence Colony, New Delhi.

Sub: - Regarding renewal of fire safety certificate in r/o M/s Jubilant Food works Ltd (Dominos Pizza) located at Shop No. 29/4, GF, Nagia Park, Shakti Nagar, Delhi-110007 Sir,

This has reference to online MHA Portal I.D. No. 2023061310778 dated 14.06.2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.06.2023 in the presence of Mr. Nand Kumar (Manager) to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection it has observed that the building/premise is comprised of basement, ground & 03 upper floors but (Restaurant is running at ground floor only). Your request for FSC is rejected under Rule 35 (3) due to following shortcomings.

- 1 The second exit door is also not qualifying the requirement of safe means of escape as this escape route is through the kitchen area of the restaurant.
- 2 Smoke ventilation system removed at ground floor.
- 3 Fire extinguisher provided but not functional.
- 4 Hose reel hose provided but not functional and nozzle damaged condition needs to be replace.
- 5 Internal hydrant provided but found not functional
- 6 Terrace level fire pump 450lpm provided but not functional at the time of inspection.
- 7 Terrace level fire water tank provided but found empty.
- 8 Exit signage's found removed at strategic location in the restaurant.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of restaurant is at your own risk & responsibility.

Yours faithfully

(Atul Garg)

Ph: 011-23414000

elc d