

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/MS/DFS/Hospital/2023/SZ/ 1412

Dated 10/07/2023

To

The Authorized Signatory,  
 Pt. Madan Mohan Malviya Hospital,  
 Malviya Nagar, New Delhi-110017.

**Sub:** -Regarding inspection / Status of GNCTD Hospital from Fire Safety point of View in June 2023 in r/o Pt. Madan Mohan Malviya Hospital, Malviya Nagar, New Delhi-110017.

Sir,

This has reference with the direction of GNCT of Delhi in r/o updated status of Government Hospitals of fire safety arrangement installed in the building. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 03.07.2023 in the presence of Mr. Devender Yadav (Supervisor) of Hospital to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 First aid hose reel provided but found nonfunctional.
- 2 Automatic detection system found partially working.
- 3 Automatic sprinkler system provided but found nonfunctional.
- 4 Internal hydrant and yard hydrant provided but found nonfunctional.
- 5 Fire fighting pumps are not on auto mode due to leakage in the main fire water piping network.

In view of above Shortcomings, the Fire Safety Certificate issued by this department vide letter of even no 321 dated 14.07.2021 is withdrawn. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
 DIRECTOR

DELHI FIRE SERVICE