

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/EH/2023/SZ/ 374

Dated: 11/07/2023

To,

M/s Chinese Wok (A unit of Lenexis Food Works
Private Limited), at Ground floor No-2A, Block C-1,
Rama Park, Uttam Nagar, Dwarka Mod, Delhi-110059.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s Chinese Wok
(A unit of Lenexis Food Works Private Limited), at Ground floor No-2A, Block C-1,Rama Park, Uttam
Nagar, Dwarka Mod, Delhi-110059.

Sir,

Please refer to your online ID No. 2023061611050 Dated 21/06/2023 on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the premises to verify the fire safety arrangements in accordance with the Delhi Fire Service Act, 2007 and Rules 2010. At the time of inspection Sh. Mukesh Kumar (Staff) was present and it was observed that the building is comprised of Ground plus three upper floors but eating house is running at ground floor only and have following shortcomings:-

1. First aid hose reel provided but not functional.
2. Down/comer system provided but not functional.
3. Terrace pump having 450 lpm output 40 m head provided but not functional.
4. Overhead water storage tank capacity of 10,000 liters provided instead of 20,000 liters.
5. Exit signage's are provided but not sufficient.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service


Copy to:-

The Joint Commissioner of Police,
Licensing Unit, Office of the Joint Commissioner of Police ,
1st Floor, Police Station, Defence Colony, New Delhi.