

C-87



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/FH/2023/SZ/162

Dated:- 11 / 07 / 2023

To
The Joint Commissioner of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s Jhankar Garden, M.G Road,
Village Aya Nagar, New Delhi

Sir,
This has reference to with MHA Portal ID 2023031603723 dated 09/06/2023 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 10.07.2023 in the presence of Mr. Sanjay Singh to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. First Aid hose reel provided but found not functional.
2. Internal and yard hydrant provided but found not functional.
3. Terrace level Fire fighting pump capacity 450 LPM provided but found not functional.
4. Exit signage's found removed at some places.

Keeping in view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
9/11/23